

Fail Report



Client: ABC **Site:** ABC COMPANY **Location:** MAINTANANCE

Asset ID: 019793 **Description:** EXTENSION LEAD **User:** J SMITH **Test Instrument:** V22-0474

Test Type	Date	Result	Unit	Status
Visual (Plugs)	1/11/2010			Fail
Visual (Flexible Cord)	1/11/2010			Pass
Visual (Cover / Guards)	1/11/2010			Pass
Overall: Fail				

Asset ID: 019794 **Description:** EXTENSION LEAD **User:** J SMITH **Test Instrument:** V22-0474

Test Type	Date	Result	Unit	Status
Visual (Plugs)	1/11/2010			Fail
Visual (Flexible Cord)	1/11/2010			Pass
Visual (Cover / Guards)	1/11/2010			Pass
Overall: Fail				

Asset ID: 019796 **Description:** POWERBOARD **User:** J SMITH **Test Instrument:** V22-0474

Test Type	Date	Result	Unit	Status
Visual (Plugs)	1/11/2010			Pass
Visual (Flexible Cord)	1/11/2010			Pass
Visual (Cover / Guards)	1/11/2010			Pass
Earth Current	1/11/2010	25	A	Information
Earth	1/11/2010	0.19	Ohm	Pass
Insulation	1/11/2010	>99.99	MOhm	Pass
Polarity	1/11/2010			Fail
Overall: Fail				

Total Tests: 3