

Realtime Test Results



Client: ABC		Site: ABC COMPANY		Location: BOARD ROOM	
Asset ID: 019810		Description: AIR CONDITIONER		User: J SMITH	
				Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status	
Visual (Plugs)	1/11/2010			Pass	
Visual (Flexible Cord)	1/11/2010			Pass	
Visual (Cover / Guards)	1/11/2010			Pass	
Earth Current	1/11/2010	25	A	Information	
Earth	1/11/2010	0.07	Ohm	Pass	
Insulation	1/11/2010	34.43	MOhm	Pass	
Overall: Pass					
Asset ID: 019811		Description: EXTENSION LEAD		User: J SMITH	
				Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status	
Visual (Plugs)	1/11/2010			Pass	
Visual (Flexible Cord)	1/11/2010			Pass	
Visual (Cover / Guards)	1/11/2010			Pass	
Earth Current	1/11/2010	25	A	Information	
Earth	1/11/2010	0.26	Ohm	Pass	
Insulation	1/11/2010	>99.99	MOhm	Pass	
Polarity	1/11/2010			Pass	
Overall: Pass					
Asset ID: 019812		Description: IEC LEAD		User: J SMITH	
				Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status	
Visual (Plugs)	1/11/2010			Pass	
Visual (Flexible Cord)	1/11/2010			Pass	
Visual (Cover / Guards)	1/11/2010			Pass	
Earth Current	1/11/2010	25	A	Information	
Earth	1/11/2010	0.21	Ohm	Pass	
Insulation	1/11/2010	>99.99	MOhm	Pass	
Polarity	1/11/2010			Pass	
Overall: Pass					
Asset ID: 019813		Description: SPEAKERS		User: J SMITH	
				Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status	
Visual (Plugs)	1/11/2010			Pass	
Visual (Flexible Cord)	1/11/2010			Pass	
Visual (Cover / Guards)	1/11/2010			Pass	
Insulation	1/11/2010	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: 019814		Description: PROJECTOR		User: J SMITH	
				Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status	
Visual (Plugs)	1/11/2010			Pass	
Visual (Flexible Cord)	1/11/2010			Pass	
Visual (Cover / Guards)	1/11/2010			Pass	
Earth Current	1/11/2010	25	A	Information	
Earth	1/11/2010	0.19	Ohm	Pass	
Insulation	1/11/2010	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: 019815		Description: OH PROJECTOR		User: J SMITH	
				Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status	
Visual (Plugs)	1/11/2010			Pass	
Visual (Flexible Cord)	1/11/2010			Pass	
Visual (Cover / Guards)	1/11/2010			Pass	
Insulation	1/11/2010	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: 019816		Description: POWER SUPPLY		User: J SMITH	
				Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status	
Visual (Plugs)	1/11/2010			Pass	
Visual (Flexible Cord)	1/11/2010			Pass	
Visual (Cover / Guards)	1/11/2010			Pass	
Insulation	1/11/2010	>99.99	MOhm	Pass	
Overall: Pass					
Asset ID: 019817		Description: COMPOSER		User: J SMITH	
				Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status	
Visual (Plugs)	1/11/2010			Pass	
Visual (Flexible Cord)	1/11/2010			Pass	
Visual (Cover / Guards)	1/11/2010			Pass	
Insulation	1/11/2010	>99.99	MOhm	Pass	

Realtime Test Results



Overall: Pass

Client: ABC	Site: ABC COMPANY	Location: MAINTANANCE
Asset ID: 015159	Description: STEREO / RADIO	User: J SMITH Test Instrument: V22-0474

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 015163	Description: PROJECTOR	User: J SMITH Test Instrument: V22-0474
------------------	------------------------	---

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.1	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 015169	Description: VHS	User: J SMITH Test Instrument: V22-0474
------------------	------------------	---

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 015170	Description: DVD	User: J SMITH Test Instrument: V22-0474
------------------	------------------	---

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 015179	Description: VAC	User: J SMITH Test Instrument: V22-0474
------------------	------------------	---

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 015182	Description: FRIDGE	User: J SMITH Test Instrument: V22-0474
------------------	---------------------	---

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.12	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 015183	Description: POWERBOARD	User: J SMITH Test Instrument: V22-0474
------------------	-------------------------	---

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.18	Ohm	Pass
Earth	2/11/2010	0.19	Ohm	Pass
Earth	2/11/2010	0.19	Ohm	Pass
Earth	2/11/2010	0.19	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Polarity	2/11/2010			Pass

Overall: Pass

Asset ID: 015185	Description: CHARGER	User: J SMITH Test Instrument: V22-0474
------------------	----------------------	---

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass

Realtime Test Results

Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: 015189	Description: DRILL	User: J SMITH	Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: 015190	Description: GRINDER	User: J SMITH	Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: 015191	Description: SOLDERING IRON	User: J SMITH	Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.1	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: 015192	Description: LIGHT / LAMP	User: J SMITH	Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: 015194	Description: LIGHT / LAMP	User: J SMITH	Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: 015196	Description: BENCH GRINDER	User: J SMITH	Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.12	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: 015201	Description: BLOWER VAC	User: J SMITH	Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Overall: Pass				

Asset ID: 015204	Description: IEC LEAD	User: J SMITH	Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.15	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Polarity	2/11/2010			Pass

Realtime Test Results

Overall: Pass

Asset ID: 019793		Description: EXTENSION LEAD		User: J SMITH		Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status			
Visual (Plugs)	1/11/2010			Fail			
Visual (Flexible Cord)	1/11/2010			Pass			
Visual (Cover / Guards)	1/11/2010			Pass			

Overall: Fail

Asset ID: 019794		Description: EXTENSION LEAD		User: J SMITH		Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status			
Visual (Plugs)	1/11/2010			Fail			
Visual (Flexible Cord)	1/11/2010			Pass			
Visual (Cover / Guards)	1/11/2010			Pass			

Overall: Fail

Asset ID: 019796		Description: POWERBOARD		User: J SMITH		Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status			
Visual (Plugs)	1/11/2010			Pass			
Visual (Flexible Cord)	1/11/2010			Pass			
Visual (Cover / Guards)	1/11/2010			Pass			
Earth Current	1/11/2010	25	A	Information			
Earth	1/11/2010	0.19	Ohm	Pass			
Insulation	1/11/2010	>99.99	MOhm	Pass			
Polarity	1/11/2010			Fail			

Overall: Fail

Client: ABC **Site: ABC COMPANY** **Location: RECEPTION**

Asset ID: 015173		Description: DVD		User: J SMITH		Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status			
Visual (Plugs)	2/11/2010			Pass			
Visual (Flexible Cord)	2/11/2010			Pass			
Visual (Cover / Guards)	2/11/2010			Pass			
Insulation	2/11/2010	>99.99	MOhm	Pass			

Overall: Pass

Asset ID: 015174		Description: POWER SUPPLY		User: J SMITH		Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status			
Visual (Plugs)	2/11/2010			Pass			
Visual (Flexible Cord)	2/11/2010			Pass			
Visual (Cover / Guards)	2/11/2010			Pass			
Insulation	2/11/2010	>99.99	MOhm	Pass			

Overall: Pass

Asset ID: 015175		Description: VHS		User: J SMITH		Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status			
Visual (Plugs)	2/11/2010			Pass			
Visual (Flexible Cord)	2/11/2010			Pass			
Visual (Cover / Guards)	2/11/2010			Pass			
Insulation	2/11/2010	>99.99	MOhm	Pass			

Overall: Pass

Asset ID: 015176		Description: CASSETT PLAYER		User: J SMITH		Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status			
Visual (Plugs)	2/11/2010			Pass			
Visual (Flexible Cord)	2/11/2010			Pass			
Visual (Cover / Guards)	2/11/2010			Pass			
Insulation	2/11/2010	>99.99	MOhm	Pass			

Overall: Pass

Asset ID: 568434		Description: COMPUTER		User: J SMITH		Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status			
Visual (Plugs)	2/11/2010			Pass			
Visual (Flexible Cord)	2/11/2010			Pass			
Visual (Cover / Guards)	2/11/2010			Pass			
Earth Current	2/11/2010	25	A	Information			
Earth	2/11/2010	0.11	Ohm	Pass			
Insulation	2/11/2010	>99.99	MOhm	Pass			

Overall: Pass

Asset ID: 568435		Description: POWER SUPPLY		User: J SMITH		Test Instrument: V22-0474	
Test Type	Date	Result	Unit	Status			
Visual (Plugs)	2/11/2010			Pass			

Realtime Test Results

Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 568436	Description: MONITOR	User: J SMITH	Test Instrument: V22-0474
------------------	----------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.26	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 568437	Description: IEC LEAD	User: J SMITH	Test Instrument: V22-0474
------------------	-----------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.15	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Polarity	2/11/2010			Pass

Overall: Pass

Asset ID: 568438	Description: SPEAKERS	User: J SMITH	Test Instrument: V22-0474
------------------	-----------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 568439	Description: POWERBOARD	User: J SMITH	Test Instrument: V22-0474
------------------	-------------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.14	Ohm	Pass
Earth	2/11/2010	0.14	Ohm	Pass
Earth	2/11/2010	0.15	Ohm	Pass
Earth	2/11/2010	0.15	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Polarity	2/11/2010			Pass

Overall: Pass

Client: ABC	Site: ABC COMPANY	Location: STAFF KITCHEN
-------------	-------------------	-------------------------

Asset ID: 014777	Description: COFFEE GRINDER	User: J SMITH	Test Instrument: 44A-0195
------------------	-----------------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Plugs	2/11/2010			Pass
Flexible cord	2/11/2010			Pass
Cover / Guards	2/11/2010			Pass
	2/11/2010	0.09	ohm	Pass
	2/11/2010	> 199	MOhm	Pass

Overall: Pass

Asset ID: 016442	Description: URN	User: J SMITH	Test Instrument: 44A-0188
------------------	------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Plugs	1/11/2010			Pass
Flexible cord	1/11/2010			Pass
Cover / Guards	1/11/2010			Pass
	1/11/2010	> 199	MOhm	Pass

Overall: Pass

Asset ID: 016443	Description: URN	User: J SMITH	Test Instrument: 44A-0188
------------------	------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Plugs	1/11/2010			Pass
Flexible cord	1/11/2010			Pass
Cover / Guards	1/11/2010			Pass
	1/11/2010	> 199	MOhm	Pass

Realtime Test Results



Overall: Pass

Asset ID: 016444		Description: POWER SUPPLY		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.062	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			
	1/11/2010			Pass			

Overall: Pass

Asset ID: 016445		Description: KETTLE		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	> 199	MOhm	Pass			

Overall: Pass

Asset ID: 016446		Description: SLOW COOKER		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.064	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			

Overall: Pass

Asset ID: 016447		Description: KETTLE BASE		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.096	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			

Overall: Pass

Asset ID: 016448		Description: KETTLE		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	> 199	MOhm	Pass			

Overall: Pass

Asset ID: 016449		Description: SANDWICH PRESS		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.088	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			

Overall: Pass

Asset ID: 016450		Description: TOASTER		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.098	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			

Overall: Pass

Asset ID: 016452		Description: COFFEE GRINDER		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.16	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			

Overall: Pass

Realtime Test Results

Asset ID: 016454		Description: COFFEE MACHINE		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.06	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			
Overall: Pass							

Asset ID: 016456		Description: KETTLE BASE		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.744	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			
Overall: Pass							

Asset ID: 016457		Description: KETTLE		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	> 199	MOhm	Pass			
	Overall: Pass						

Asset ID: 016459		Description: MICROWAVE		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.07	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			
Overall: Pass							

Asset ID: 016460		Description: FRIDGE		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.11	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			
Overall: Pass							

Asset ID: 016461		Description: VENDING		User: J SMITH		Test Instrument: 44A-0188	
Test Type	Date	Result	Unit	Status			
Plugs	1/11/2010			Pass			
Flexible cord	1/11/2010			Pass			
Cover / Guards	1/11/2010			Pass			
	1/11/2010	0.152	ohm	Pass			
	1/11/2010	> 199	MOhm	Pass			
Overall: Pass							

Client: ABC		Site: ABC COMPANY		Location: STAFF TOILET			
Asset ID: 014705		Description: HAIR DRYER		User: J SMITH		Test Instrument: 44A-0195	
Test Type	Date	Result	Unit	Status			
Plugs	2/11/2010			Pass			
Flexible cord	2/11/2010			Pass			
Cover / Guards	2/11/2010			Pass			
	2/11/2010	0.066	ohm	Pass			
	2/11/2010	> 199	MOhm	Pass			
Overall: Pass							

Client: ABC		Site: ABC COMPANY		Location: UTILITY ROOM			
Asset ID: 014731		Description: PHOTOCOPIER		User: J SMITH		Test Instrument: 44A-0195	
Test Type	Date	Result	Unit	Status			
Plugs	2/11/2010			Pass			
Flexible cord	2/11/2010			Pass			
Cover / Guards	2/11/2010			Pass			
	2/11/2010	0.118	ohm	Pass			
	2/11/2010	> 199	MOhm	Pass			
Overall: Pass							

Realtime Test Results

Asset ID:	Description:	User:	Test Instrument:	
014732	IEC LEAD	J SMITH	44A-0195	
Test Type	Date	Result	Unit	Status
Plugs	2/11/2010			Pass
Flexible cord	2/11/2010			Pass
Cover / Guards	2/11/2010			Pass
	2/11/2010	0.116	ohm	Pass
	2/11/2010	> 199	MOhm	Pass
	2/11/2010			Pass
				Overall: Pass
015165	MONITOR	J SMITH	V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.11	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
				Overall: Pass
015166	POWER SUPPLY	J SMITH	V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.11	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
				Overall: Pass
015186	STAPLER	J SMITH	V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
				Overall: Pass
015187	STAPLER	J SMITH	V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
				Overall: Pass
015197	EXTENSION LEAD	J SMITH	V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.66	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Polarity	2/11/2010			Pass
				Overall: Pass
015199	TIMER	J SMITH	V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.14	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Polarity	2/11/2010			Pass
				Overall: Pass
015200	SAFETY SWITCH	J SMITH	V22-0474	
Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass

Realtime Test Results

Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.14	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass
Polarity	2/11/2010			Pass

Overall: Pass

Asset ID: 015203	Description: ROUTER	User: J SMITH	Test Instrument: V22-0474
------------------	---------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Earth Current	2/11/2010	25	A	Information
Earth	2/11/2010	0.16	Ohm	Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Asset ID: 015207	Description: LAPTOP PSU	User: J SMITH	Test Instrument: V22-0474
------------------	-------------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	35.23	MOhm	Pass

Overall: Pass

Asset ID: 015208	Description: POWER SUPPLY	User: J SMITH	Test Instrument: V22-0474
------------------	---------------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	35.13	MOhm	Pass

Overall: Pass

Asset ID: 015209	Description: POWER SUPPLY	User: J SMITH	Test Instrument: V22-0474
------------------	---------------------------	---------------	---------------------------

Test Type	Date	Result	Unit	Status
Visual (Plugs)	2/11/2010			Pass
Visual (Flexible Cord)	2/11/2010			Pass
Visual (Cover / Guards)	2/11/2010			Pass
Insulation	2/11/2010	>99.99	MOhm	Pass

Overall: Pass

Total Tests: 68